Office of the Deputy Director, Fire & Emergency Services
Command Jammu

The Principal
Shaurya International School
Jeevan Nagar, Babliana
Jammu

No: DDF&ES/CJ/FP/2026/ 3118 Dated: 18.09.2026

Sub: Fire & Life Safety Measures/Guidelines.
Ref: Your online application submission dated: 21.08.2026 (FI026-62942632nb).

Sir,

The spot inspection of above said school was got carried out by the inspecting officer of this department. During inspection, it was found that the management has installed Hose Reel Hoses and First Aid Fire Extinguishers in their school premises. Besides this, two overhead water storage tanks of 50 KL capacity each and one underground water storage tank of 70 KL capacity is also available. Moreover, the school is about 06 Km away from Fire and Emergency Station Gangyal and is approachable for fire appliances in case of any emergency. Since the school is already functioning. As such, the management can proceed ahead for operation subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith:-

1. Fire Hydrants (i.e. external as well as internal) shall be installed at appropriate places of the entire both blocks of the school premises with provision of two lengths of delivery fire hose and a branch be kept in a Red Panel Box near each hydrant. The fire hydrants should be installed in such a way where from every nook and corner of the entire both blocks of the school premises are covered easily at the time of any emergency.
2. 01 No. of CO_2 Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
3. All exit/entrances should be kept open and free from any obstruction for quick and safe evacuation of inmate during any emergency.
4. First Aid Firefighting system installed in the school building should be checked periodically. Staff and management should be fully trained in handling / operating of firefighting system installed in the school building.
5. All electric installations existing in the building should be concealed conduit type.
6. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
7. The corridor of the building shall not be used for any kind of storage.
8. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, these fire safety recommendations/guidelines will be treated automatically withdrawn/cancelled.
9. The management shall be wholly and solely responsible for keeping the firefighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is having two inter connected blocks, both are four storied. As such, no addition / alteration should be made by the management in the existing structure without prior information from this department.
11. In the event that the management failed to install/comply with the fire safety measures/recommendations given in this letter, the validity of this letter shall be deemed withdrawn / cancelled automatically.
12. **These instant fire safety recommendations/guidelines is strictly for adoption of fire safety measures/ guidelines of the occupancy only and not for authentication of any other claim.**
13. **These fire safety recommendations/guidelines shall be subject to outcome of any dispute/ investigation/enquiry/ trial if any, pending before any Court of Law/Investigation agency. These fire safety recommendations/guidelines shall not confirm any title upon the person/company in whose favour it is issued. Further, the status with regard to land shall be the responsibility of the concerned registering authority.**
14. The validity of these fire safety recommendations/guidelines shall remain in force for two years subject to the condition that the department of Fire & Emergency Services J&K will conduct half yearly surprise checks of the fire safety installations. In case of any defects found in the operational capabilities of the Fire Safety Equipment or expiry of the service-life of any of the equipment or alteration in the already existing building infrastructure, the validity of these fire safety recommendations/guidelines shall be treated automatically withdrawn/ cancelled.

Yours Faithfully

Deputy Director
Fire & Emergency Services
Command Jammu